



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the	Bughan Singh Academy, 200, 333, 332		
Sample taken from	SUBMERCIBLE		
Date of sample Drawn	20/4/2026		
Date of analysis	20/4/2026		
Physical Character	TRANSPARENT / COLOURLESS		
P. H. Value	8.42		
Free Ammonia Parts per 1000000	NIL		
Albuminoid Ammonia Part per 1000000	NIL		
Oxygen absorbed from pot. Permagnate in three hours at 37° C	0.4		
Chloride Part per 1000000	40.00		
Nitrates Parts per 1000000	TRACES		
Nitrates Parts per 1000000	TRACES		
Total solid part per 100000	420.00		
Fixed solid Parts per 1000000	362.00		
Volatils solid Parts per 100000	66.00		
Appearance on ignition	NO CHARRING		
Total hardness Parts per 1000000	204.00		
Permanent hardness Parts per 1000000	168.00		
Temporary hardness Parts per 1000000	36.00		

K.N.N. PRESS

Remarks : POTABLE

No. 419/SWA/chem dated 25/04/2026

Copy forwarded for favour or information to

1) w/s Bughan Singh Academy,
P.No:- 200, 290, 330, 332, 333
Khadepur, Kasrali road, Kanpur

2) N.S.A. Kanpur Nagar Nigam

Nagar Swasthya Adhikari
Nagar Nigam Kanpur

KALKA SINGH
(Chemist)
Nagar Nigam Kanpur

D.No. 2 419/SWR/CHEM 28/4/2026



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from Sughas Singh Academy Plot No:- 200, 290, 330, 332
Name & designation of the person collecting samples... ALKA SINGH - CHEMIST 333, Khadepur, Faizki Road
Kanpur Nagar

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count			Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS	
		at 37.c in 48 hours	at room temp- return in 72 hours	Quantity of water put in each tube No of tubes put up	50ML 1	10 ML 5				1 ML 5
20/4/2026	'SUSMERGIBLE'	'10'	'66'	—	NIL	'2'	'1'	'ZERO'	NIL	'Satisfactory'

Remark:- Chlorination is very necessary / P.R.C. must be 0.2 ppm.

- Copy for Information Forwarded to
- (1) Sughas Singh Academy.
 - (2) M.S. A Kanpur Nagar Nigam

ALKA SINGH अधिकारी
(Chemist)
Nagar Nigam Kanpur

Nages Swadhyaya Adhikari
कां. निगम कां. निगम

Technova Pvt. Ltd. USR 18022903050 0294C16